# **PNEUMATIC ACTUATORS** INSTALLATION AND MAINTENANCE





www.diteico.com 23-03 V1



### **INDEX**

- 1. Directions for actuator installation
- 2. Installation operation
- 3. AISI 316 (A4) stainless steel "CH-A" series actuators notice and notes for actuators use in explosive environments ATEX 2014/34/UE directive
- 4. Assembly variations
- 5. Aluminium "CH" actuators spare-part sets and springs
- 6. AISI 316 (A4) stainless steel "CH-A" actuators spare-part sets and springs
- 7. Rotation adjustment
- 8. Maintenance, spare-part set and springs substitution



### **DIRECTIONS FOR ACTUATOR INSTALLATION**

#### Valid for both, aluminium "CH-A Series" and AISI 316 (A4) Stainless Steel "CH-A Series", actuators.

Duration and safety use of actuators and plants, for all operators within their range of action, also depends on the attention paid to the following directions.

- Move carefully, without crashes.
- Keep actuators in their original packaging, with the relevant contents slips.
- Stock in warehouse between 0° C and + 40° C., even for long periods.
- Construction materials, surface treatments and paintings are physically steady and chemically inactive only under the conditions which are indicated on the identification nameplate.
- Possible arising of oily fogs inside the device: filtrate exhaust feeding air or recycle through specific solenoid-valves.
- Actuator's lubrication is made by the manufacturer. Its operation warranty, identified as number of movements before main metallic part substitution, is 1.000.000 manoeuvres (opening and closing). It is referred to standard models only.
- Springs operation, is guaranteed for 100.000 manoeuvres (opening and closing) before it has to be tested: they must be substituted in case of corrosion marks, wear or side yield.
- Antifriction plastic parts and rubber seals identified as "spare parts set" operation, is guaranteed for 300.000
  manoeuvres (opening and closing) before it has to be tested: they must be substituted in case of corrosion marks
  or pressure losses.
- Installation of the actuator is forbidden before the plant is declared in accordance to CE norms or to eventual technical norms that must regulate the plant's working.

### ALUMINIUM "CH-AIR" SERIES ACTUATORS NOTICE AND NOTES FOR ACTUATORS USE IN EXPLOSIVE ENVIRONMENTS ATEX - 2014/34/UE DIRECTIVE

"CH" Series Rack & Pinion Actuators in aluminium alloy are carefully engineered and manufactured according to the relevant technical norms and safety european directives.

They can be used in ATEX - 2014/34/UE Directive dangerous zones, according to the following manufacturer classification.

#### Device Group II (surface) - Category 2 - G (gas) and D (dust) use

Low Temperature	-40 +80°C (-40 +176°F)	(Ex)	II 2GD c Tmax = 95°C (203°F)
Standard	-20 +80°C (-4 +176°F)	× Ex	II 2GD c Tmax = 95°C (203°F)
High Temperature	-20 +150°C (-4 +302°F)	(Ex)	II 2GD c Tmax = 165°C (203°F)

## Due to the relevant safe condition needs, for CH applications in that particular environment, carefully read please the above notices.

- · Before installation, please read our "Instruction manual for use and maintenance" carefully.
- Follow the use expected for actuators.
- · Follow the indications of maximum temperature-environment of use, punched on identification nameplate.
- Don't let the actuator be fed by flammable, explosive or burning fluids (oxygen, acetylene etc...).
- Avoid the penetration of explosive atmospheres inside actuators.
- Do not hit the external parts of actuators (both aluminium and steel parts) through metallic objects (it may cause sparkles).
- Do not manually force actuators over the maximum output torque.
- · Avoid accumulation of combustible dusts on actuator surfaces.
- Avoid accumulation of electrostatic charges on insulating surfaces of CH-A, by providing suitable "grounding", using for example the valve fixing screws.
- All components and accessories installed on CH-A for drive and control purposes, must be suitable for those uses in accordance to the danger classification of the area.
- Maintenance operations on actuators must be made according to the norms in force, (for example EN 50281, EN 60079 etc...) and to the danger classification of the area.
- · Do not make maintenance operations in places with explosive atmosphere.
- Verify springs functioning every 100.000 (one hundred thousand) cycles: substitute complete spring cartridges when necessary, but do not try to disassembly them.
- Verify all rubber sealing elements (o-ring s and plane gaskets) and all plastic anti-friction pads every 300.000 (three hundred thousan) cycles: substitute the complete spare-parts set when necessary.
- Use and operation not in accordance to a.m. notes, may cause danger or damage to people and things, and let every legal responsibility lose from Manufacturer side.



### **INSTALLATION OPERATION**

#### Valid for both, aluminium "CH Series" and AISI 316 (A4) Stainless Steel "CH Series", actuators.

For a safe install operation, follow please the above procedure.



#### Disassembly is made following all described operations, backwards.

Pay attention to safety rules.

In case of difficulty, do not force the elements, but verify clearances, axis position, supplied feeding and correct torque dimensioning of valve and actuator.



### AISI 316 (A4) STAINLESS STEEL "CH-A" SERIES ACTUATORS - NOTICE AND NOTES FOR ACTUATORS USE IN EXPLOSIVE ENVIRONMENTS ATEX - 2014/34/UE DIRECTIVE

"CH-A" Series Rack & Pinion Actuators in AISI 316 (A4) Stainless Steel are carefully engineered and manufactured according to the relevant technical norms and safety european directives.

They can be used in ATEX - 2014/34/UE Directive dangerous zones, according to the following manufacturer classification.

#### Device Group I (mines) - Category M2 - G (gas) and D (dust) use

Device Group II (surface) - Category 2 - G (gas) and D (dust) use

Low Temperature	-40 +80°C (-40 +176°F)	(Ex)	I M2 \ II 2GD c Tmax = 95°C (203°F)
Standard	-20 +80°C (-4 +176°F)	× Ex	l M2 \ II 2GD c Tmax = 95°C (203°F)
High Temperature	-20 +150°C (-4 +302°F)	(Ex)	I M2 \ II 2GD c Tmax = 165°C (203°F)

# Due to the relevant safe conditions needs, for CH CH applications in that particular environment, carefully read please the above notices.

- · Before installation, please read our "Instruction manual for use and maintenance" carefully.
- Follow the use expected for actuators.
- · Follow the indications of maximum temperature-environment of use, punched on identification nameplate.
- · Don't let the actuator be fed by flammable, explosive or burning fluids (oxygen, acetylene etc...).
- Avoid the penetration of explosive atmospheres inside actuators.
- Do not hit the external parts of actuators (both aluminium and steel parts) through metallic objects (it may cause sparkles).
- Do not manually force actuators over the maximum output torque.
- · Avoid accumulation of combustible dusts on actuator surfaces.
- Avoid accumulation of electrostatic charges on insulating surfaces of CH-A, by providing suitable "grounding", using for example the valve fixing screws.
- All components and accessories installed on CH-A for drive and control purposes, must be suitable for those uses in accordance to the danger classification of the area.
- Maintenance operations on actuators must be made according to the norms in force, (for example EN 50281, EN 60079 etc...) and to the danger classification of the area.
- · Do not make maintenance operations in places with explosive atmosphere.
- Verify springs functioning every 100.000 (one hundred thousand) cycles: substitute complete spring cartridges
  when necessary, but do not try to disassembly them.
- Verify all rubber sealing elements (o-ring s and plane gaskets) and all plastic anti-friction pads every 300.000 (three hundred thousand) cycles: substitute the complete spare-parts set when necessary.
- Use and operation not in accordance to a.m. notes, may cause danger or damage to people and things, and let every legal responsibility lose from Manufacturer side.



### **ASSEMBLY VARIATIONS**

Valid for both aluminium "CH" and AISI 316 (A4) Stainless Steel "CH-A" actuators. There are four different assembly variations that are able to solve every need of valve/actuator placing combined with fail occurrence (fail-safe). They are mainly used for Spring Return "SR" operation.

The position of the upper part of actuator's shaft has to indicate the position of the valve. **Standard assembly variation** is: "A".

P.N. According to ISO 5211 - DIN 3337, closing rotation of the valve has to be clockwise.

TYPE	ASSEMBLY SCHEME	TYPICAL CHPLICATION	UTILITY
A	Aria		SPRINGS CLOSE THE VALVE In event of fail, the valve is closed (fail-safe).
В	Aria		SPRINGS CLOSE THE VALVE In event of fail, the valve is closed (fail-safe).
С			SPRINGS OPEN THE VALVE In event of fail, the valve is opened.
D	Aria		SPRINGS OPEN THE VALVE In event of fail, the valve is opened.



### **ALUMINIUM "CH" ACTUATORS - SPARE-PART SETS AND SPRINGS**

Please note that, depending on working conditions of the actuator, it may be necessary to make a "spare-part set" periodic substitution, this means a change of all antifriction plastic parts and of all rubber seals. Their lifetime duration is guaranteed only for 300.000 manoeuvres (opening and closing), before a new inspection comes to be necessary: in case of corrosion marks or pressure losses, these parts must be substituted.

It may be also necessary to substitute a "spare-part set" for use at a different working temperature. In this case, please verify that both "spare-part set" and lubricant are suitable for the new environmental conditions (see "Actuator working temperatures" datasheet).

Please remember that springs lifetime duration is guaranteed only for 100.000 manoeuvres (opening and closing), before a new inspection comes to be necessary: they must be substituted in case of corrosion marks, wear or side yield.

This is a list of "spare-part set" and springs.



PART	QUANTITY	DESCRIPTION	MATERIAL	SPECIFICATION	PROTECTION
5*	2	Antiejection key	Acetalic Resin – PA66 – PA66		
6*	1	Lower shaft O-Ring	NBR - FPM\FKM - Silicone		
7*	1	Upper shaft O-Ring	NBR - FPM\FKM - Silicone		
10*	1	Seeger ring	Carbon steel		Nickel plating
11	012	Spring cartridge	Carbon+Stainless Steel, PA 66	AISI 304 (A2)	Painting
12*	2	Piston O-Ring	NBR - FPM\FKM - Silicone		
13*	2	Piston head bearing	Acetalic Resin – PA66 – PA66		
14*	2	Cover gasket	NBR - FPM\FKM - Silicone		
19*	2	O-Ring	NBR - FPM\FKM - Silicone		
23*	1	Shaft thrust washer	Stainless Steel	AISI 304 (A2)	
24*	1	Shaft antifriction washer	Acetalic Resin – PA66 – PA66		
25*	1	Lower shaft pilot ring	Acetalic Resin – PA66 – PA66		
26*	1	Upper shaft pilot ring	Acetalic Resin – PA66 – PA66		
27*	2-4	Piston bearing	Acetalic Resin – PA66 – PA66		

\* Standard SPARE-PARTS SET in NBR - Special HIGH Temperature in FPM\FKM - Special LOW Temperature in Silicone



### AISI 316 (A4) STAINLESS STEEL "CH-A" ACTUATORS -SPARE-PART SETS AND SPRINGS

Please note that, depending on working conditions of the actuator, it may be necessary to make a "spare-part set" periodic substitution, this means a change of all antifriction plastic parts and of all rubber seals. Their lifetime duration is guaranteed only for 300.000 manoeuvres (opening and closing), before a new inspection comes to be necessary: in case of corrosion marks or pressure losses, these parts must be substituted.

It may be also necessary to substitute a "spare-part set" for use at a different working temperature. In this case, please verify that both "spare-part set" and lubricant are suitable for the new environmental conditions (see "Actuator working temperatures" datasheet).

Please remember that springs lifetime duration is guaranted only for 100.000 manoeuvres (opening and closing), before a new inspection comes to be necessary: they must be substituted in case of corrosion marks, wear or side yield.

This is a list of "spare-part set" and springs.



PART	QUANTITY	DESCRIPTION	MATERIAL	SPECIFICATION	PROTECTION		
5*	2	Antiejection key	Acetalic Resin – PA66 – PA66				
6*	1	Lower shaft O-Ring	NBR - FPM\FKM - Silicone				
7*	1	Upper shaft O-Ring	NBR - FPM\FKM - Silicone				
10*	1	Seeger ring	Carbon steel		Nickel plating		
11	012	Spring cartridge	Carbon+Stainless Steel, PA 66	AISI 304 (A2)	Painting		
12*	2	Piston O-Ring	NBR - FPM\FKM - Silicone				
13*	2	Piston head bearing	Acetalic Resin – PA66 – PA66				
14*	2	Cover gasket	NBR - FPM\FKM - Silicone				
19*	2	O-Ring adjustment	NBR - FPM\FKM - Silicone				
23*	1	Shaft thrust washer	Stainless Steel	AISI 304 (A2)			
24*	1	Shaft antifriction washer	Acetalic Resin – PA66 – PA66				
25*	1	Lower shaft pilot ring	Acetalic Resin – PA66 – PA66				
26*	1	Upper shaft pilot ring	Acetalic Resin – PA66 – PA66				
27*	2	Piston bearing	Acetalic Resin – PA66 – PA66				
33*	2	O-Ring for NAMUR plate	NBR - FPM\FKM - Silicone				
* S	* Standard SPARE-PARTS SET in NBR - Special HIGH Temperature in FPM\FKM - Special LOW Temperature in Silicone						

ç



### **ROTATION ADJUSTMENT**

#### Valid for both, aluminium "CH Series" and AISI 316 (A4) Stainless Steel "CH-A Series", actuators.

Rotation adjustment of 90°-120°-180° actuators, is made by high precision electronic device, and normally not require further adjustment operation. In event of need, by mean cover and piston travel-stop screw, you can adjust +\- 5° the actuator rotat ion in both opening and closing directions. The below figures shows the rotation adjustment operations, as also described in every actuator handbook.

#### **ADJUSTMENT IN CLOSING - 0°**

Warning! Installation, adjustment and maintenance must be effected under safety conditions. Don't connect pneumatic/electrical feeding until all operations are terminated.



Take off covers loosening screws as per indicated numeration; pull out springs, if any, from pistons seats.



Unscrew counter-bolt and dowel for regulation of the piston's travel from both sides of actuator.



Keep the stem slightly in tension, (by fix key for ball valves and by special dynamometrical key for butterfly valves) and regulate rotation of the actuator in closing (0°) on one side, adjusting piston's travel through the regulation dowel.



When reaching the wanted point of enclosure, keep the regulation dowel in position and tighten the counter-bolt. Repeat this operation on the other side of the actuator.

- Re-assembly springs, if any, and covers tightening screws a little at a time following the numeration.
- Connect pneumatic/electrical feeding and verify correct operation.



### **ROTATION ADJUSTMENT**

Valid for both, aluminium "CH Series" and AISI 316 (A4) Stainless Steel "CH-A Series", actuators.

#### **ADJUSTMENT IN CLOSING - 90°**

Warning! Installation, adjustment and maintenance must be effected under safety conditions. Don't connect pneumatic/electrical feeding until all operations are terminated.



Unscrew counter-bolt and regulation dowel on both covers.





Connect air feeding into port "A-2" to have actuator's opening.



When reaching the wanted point of opening, keep regulation dowel in position and tighten counter-bolt. Repeat this operation on the other side of the actuator.

 Connect pneumatic/electrical feeding and verify correct operation





### **MAINTENANCE, SPARE-PART SET AND SPRINGS SUBSTITUTION**

#### Valid for both, aluminium "CH Series" and AISI 316 (A4) Stainless Steel "CH-A Series", actuators.

In event of "spare-part set" and\or spring substitution, follow please the above procedure also listed on actuator handbook (held inside every actuator box).

### MAINTENANCE, SPARE PARTS SET AND SPRING SUBSTITUTION

Warning! Installation, adjustment and maintenance must be effected under safety conditions. Don't connect pneumatic/electrical feeding until all operations are terminated.





3

Rotate stem in order to release pistons from 0 shaft's rack. Take off pistons through a pair of pincers. Take out 4 10 23 24 Release 6  $\bigcirc$ 0 0 0 20 Release seeger ring (part 10) from stem and take away: pinion thrust washer (part 23) and antifriction washer (part. 24). 0 Extract shaft from actuator's body and take off: 26 upper pilot ring for shaft (part 26), Orings (part 06-07 07), lower pilot ring for shaft (part 25), Take out 06



25





















ightarrow index







